

# TEST CERTIFICATE

FOR TEST REPORT 21-0038-B [H-FRAME]

## SCAFEAST SCAFFOLD AND FORMWORK PTY LTD

ATTENTION: JACK SI  
13 B MONTEREY ROAD  
DANDENONG SOUTH VIC 3175

EQUIPMENT DESIGNATION: *Scafeast H-Frame Formwork Shoring Frame Assemblies*

TEST METHOD REFERENCE: *AS 3610 – 1995*

SCAFEAST FORMWORK SHORING FRAME ASSEMBLIES HAVE BEEN  
LOAD TESTED IN ACCORDANCE WITH  
AS 3610 – 1995 FORMWORK FOR CONCRETE  
AND HAVE PASSED THE TEST  
FOR LOAD BEARING CAPACITY.

SCAFEAST H-FRAME FORMWORK ASSEMBLIES CONSISTING OF TWO, 1.8M HIGH  
BRACED FRAMES ERECTED WITH BASE AND U-HEAD JACKS CONFIGURED TO 600MM  
WITH A TOTAL ASSEMBLY HEIGHT OF 3.0M SUPPORTED ULTIMATE TEST LOADS  
COMMENSURATE WITH WORKING LOAD LIMITS (WLL) AS FOLLOWS:

**65kN** WITH ECCENTRICITIES IN THE BRACE DIRECTION  
**67kN** WITH ECCENTRICITIES IN THE FRAME DIRECTION

### Notes:

1. Melbourne Testing Services (MTS) Pty Ltd shall not be liable for loss, cost, damages or expenses incurred by the client or any other person or company, resulting from the use of any information or interpretation given in test report no. 21-0038-B. In no case shall Melbourne Testing Services Pty Ltd be liable for consequential damages including, but not limited to, lost profit, damages for failure to meet deadlines and lost production arising from test report no. 21-0038-B. This document shall not be reproduced except in full and relates only to the items tested.
2. The test report no. 21-0038-B only indicates compliance of the formwork frame assemblies in their state at the time of testing. It should not be taken as a statement that all similar formwork frame assemblies or components in all states of repair, would also be found to comply.
3. It remains the responsibility of the client to ensure that the formwork frame assemblies as reported in test report no. 21-0038-B are representative of the entire production batch.
4. MTS advises the reader that compliance is strictly limited to the load bearing performance of the formwork assemblies and the provisions of technical information as provided in Report No. 21-0038-B. This document makes no assessment of any other requirements as specified by Australian or international standards that may apply.
5. MTS shall take no responsibility for the procurement and authenticity of the formwork frame assemblies as described in test report no. 21-0038-B.
6. MTS shall take no responsibility for the installation procedures used for the formwork frame assemblies described in test report no. 21-0038-B.
7. The WLL's reported herein are valid only when the formwork frame assemblies are manufactured, installed, and used in strict accordance with the requirements of AS3610-1995, AS3610-1996 Supplementary 2 & AS3610.1-2010.



**ROD WILKIE**  
AUTHORISED SIGNATORY  
DATE: 06/06/2021